



Environmental Compliance Report

Sewage Treatment Plant Flow Summary
 Environment Protection Licence: 587, 579, 803 & 2564
 EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2			
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
1/01/2024	191	196	0		974		1,721		472	
2/01/2024	210	184	0		900		1,668		365	
3/01/2024	201	261	0		922		1,668		340	
4/01/2024	190	83	0		855		1,572		313	
5/01/2024	204	261	0		849		1,657		294	
6/01/2024	196	203	0		883		1,612		305	
7/01/2024	184	212	0		779		1,525		279	
8/01/2024	182	183	0		537		1,508		261	
9/01/2024	177	181	0		0		1,422		257	
10/01/2024	174	189	0		1,217		1,422		252	
11/01/2024	191	167	0		1,249		1,445		257	
12/01/2024	187	140	0		1,115		1,421		250	
13/01/2024	186	268	0		749		1,370		249	
14/01/2024	186	101	0		773		1,421		251	
15/01/2024	757	331	0		837		2,306		330	
16/01/2024	2,028	674	0		2,505		2,715		461	
17/01/2024	719	497	0		1,546		1,952		321	
18/01/2024	1,037	398	0		1,133		2,307		286	
19/01/2024	737	629	0		964		1,864		262	
20/01/2024	378	392	0		914		1,496		249	
21/01/2024	288	28	0		820		1,438		231	
22/01/2024	249	295	0		555		1,414		226	
23/01/2024	229	229	0		568		1,311		227	
24/01/2024	228	305	0		1,406		1,419		224	
25/01/2024	203	58	0		503		1,389		214	
26/01/2024	198	200	0		830		1,405		235	
27/01/2024	280	233	0		659		1,888		248	
28/01/2024	347	317	0		1,122		2,356		305	
29/01/2024	574	187	0		1,373		3,638		467	
30/01/2024	357	311	0		1,376		1,797		272	
31/01/2024	276	305	0		1,580		1,568		216	
1/02/2024	230	199	0		944		1,445		201	
2/02/2024	203	140	0		630		1,377		190	
3/02/2024	205	185	0		893		1,284		194	
4/02/2024	195	264	0		786		1,426		206	
5/02/2024	187	162	0		571		1,336		197	
6/02/2024	194	176	0		0		1,308		179	
7/02/2024	359	329	0		1,379		1,732		234	
8/02/2024	225	233	0		787		1,318		176	
9/02/2024	200	160	0		892		1,366		189	
10/02/2024	195	166	0		830		1,315		196	



Environmental Compliance Report

Sewage Treatment Plant Flow Summary

Environment Protection Licence: 587, 579, 803 & 2564

EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2			
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
11/02/2024	834	294	0		863		2,254		243	
12/02/2024	685	496	0		1,893		1,697		226	
13/02/2024	361	328	0		1,133		1,429		190	
14/02/2024	262	288	0		827		1,341		180	
15/02/2024	223	234	0		880		1,355		173	
16/02/2024	260	225	0		1,267		2,035		399	
17/02/2024	234	280	0		1,376		1,585		264	
18/02/2024	218	199	0		830		1,501		214	
19/02/2024	1,088	204	0		2,177		1,501		312	
20/02/2024	981	448	0		2,541		2,870		453	
21/02/2024	472	371	0		1,778		1,828		254	
22/02/2024	321	270	0		547		1,580		235	
23/02/2024	260	335	0		516		1,520		224	
24/02/2024	329	228	0		1,369		1,555		231	
25/02/2024	507	438	0		1,274		2,975		545	
26/02/2024	358	352	0		1,057		1,780		295	
27/02/2024	262	297	0		995		1,356		223	
28/02/2024	236	224	0		996		1,337		210	
29/02/2024	216	231	0		997		1,345		205	
1/03/2024	198	195	0		996		1,327		210	
2/03/2024	941	210	0		947		4,393		418	
3/03/2024	1,183	285	0		1,605		3,087		378	
4/03/2024	476	442	0		3,036		1,664		308	
5/03/2024	375	343	0		745		1,525		256	
6/03/2024	311	403	0		1,356		1,471		225	
7/03/2024	265	166	0		1,375		1,375		209	
8/03/2024	227	269	0		1,092		1,296		193	
9/03/2024	254	271	0		882		1,360		208	
10/03/2024	293	229	0		896		1,385		198	
11/03/2024	318	328	0		870		1,375		200	
12/03/2024	241	281	0		869		1,303		188	
13/03/2024	170	211	0		869		1,289		188	
14/03/2024	256	231	0		869		1,275		195	
15/03/2024	187	193	0		995		1,328		199	
16/03/2024	392	351	0		994		1,770		284	
17/03/2024	254	240	0		996		1,273		224	
18/03/2024	222	263	0		995		1,567		256	
19/03/2024	217	226	0		758		1,395		222	
20/03/2024	785	159	0		1,371		1,556		324	
21/03/2024	972	605	0		1,875		1,529		371	
22/03/2024	459	360	0		868		1,352		255	



Environmental Compliance Report

Sewage Treatment Plant Flow Summary
 Environment Protection Licence: 587, 579, 803 & 2564
 EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2			
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
23/03/2024	337	312	0		891		1,337		234	
24/03/2024	284	298	0		995		1,289		208	
25/03/2024	267	295	0		1,122		1,362		221	
26/03/2024	233	268	0		1,094		1,252		197	
27/03/2024	219	224	0		941		1,252		197	
28/03/2024	183	225	0		913		1,438		223	
29/03/2024	262	195	0		1,122		1,839		286	
30/03/2024	301	349	0		1,121		1,581		297	
31/03/2024	240	274	0		1,123		1,474		297	
1/04/2024	241	250	0		999		1,497		266	
2/04/2024	226	211	0		645		1,388		228	
3/04/2024	204	204	0		1,138		1,337		206	
4/04/2024	706	213	0		1,857		4,948		637	
5/04/2024	2,953	399	0		7,421		4,514		1,802	
6/04/2024	1,431	543	0		8,379		4,079		825	
7/04/2024	1,989	618	0		7,965		9,286		1,648	
8/04/2024	747	636	0		4,068		3,083		514	
9/04/2024	521	513	0		1,748		2,263		491	
10/04/2024	418	383	0		3,026		1,919		444	
11/04/2024	330	303	0		1,825		1,697		315	
12/04/2024	281	262	0		984		1,655		283	
13/04/2024	250	291	0		994		1,600		273	
14/04/2024	240	177	0		994		1,563		266	
15/04/2024	229	297	0		1,247		1,486		269	
16/04/2024	857	203	0		2,845		2,587		309	
17/04/2024	694	611	0		3,277		2,035		309	
18/04/2024	414	285	0		1,535		1,660		295	
19/04/2024	330	399	0		1,132		1,683		295	
20/04/2024	313	227	0		741		1,791		284	
21/04/2024	319	317	0		1,355		1,866		301	
22/04/2024	272	318	0		1,499		1,648		268	
23/04/2024	303	302	0		1,625		1,851		268	
24/04/2024	269	296	0		1,359		1,580		273	
25/04/2024	246	276	0		1,191		1,507		261	
26/04/2024	232	10	0		1,099		1,554		265	
27/04/2024	225	274	0		1,104		1,495		243	
28/04/2024	229	211	0		1,090		1,505		217	
29/04/2024	214	154	0		846		1,482		198	
30/04/2024	210	50	322		151		1,481		191	
1/05/2024	212	0	73		1,425		1,087		179	
2/05/2024	221	0	225		995		1,330		191	



Environmental Compliance Report

Sewage Treatment Plant Flow Summary

Environment Protection Licence: 587, 579, 803 & 2564

EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2			
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
3/05/2024	229	0	232		2,638		1,562		193	
4/05/2024	224	0	314		537		1,927		220	
5/05/2024	221	0	240		868		1,553		212	
6/05/2024	289	0	228		1,969		2,065		227	
7/05/2024	1,827	0	660		5,314		5,061		1,144	
8/05/2024	749	0	718		3,021		5,061		527	
9/05/2024	1,014	0	710		3,005		4,902		697	
10/05/2024	799	0	694		3,016		2,742		514	
11/05/2024	1,443	0	632		5,196		4,800		1,388	
12/05/2024	1,097	0	746		6,480		4,722		969	
13/05/2024	597	0	578		1,113		2,497		456	
14/05/2024	426	0	381		2,766		1,950		343	
15/05/2024	342	0	345		2,383		1,807		296	
16/05/2024	305	0	349		2,131		1,701		277	
17/05/2024	295	0	292		986		1,542		264	
18/05/2024	285	0	289		994		1,629		268	
19/05/2024	270	0	258		993		1,560		255	
20/05/2024	248	0	194		1,247		1,444		232	
21/05/2024	235	0	280		2,699		1,363		217	
22/05/2024	208	0	268		1,874		1,430		206	
23/05/2024	211	0	219		361		1,385		205	
24/05/2024	199	0	216		994		1,369		212	
25/05/2024	199	0	207		994		1,374		210	
26/05/2024	209	0	218		995		1,374		215	
27/05/2024	207	0	206		1,120		1,397		198	
28/05/2024	201	0	220		883		1,062		192	
29/05/2024	190	0	194		2,246		1,292		196	
30/05/2024	188	0	211		2,084		1,319		190	
31/05/2024	182	0	190		900		1,254		182	
1/06/2024	565	0	197		1,692		2,459		529	
2/06/2024	475	0	575		2,648		1,871		450	
3/06/2024	323	0	323		1,518		1,607		289	
4/06/2024	262	0	283		718		1,454		244	
5/06/2024	236	0	161		899		1,418		221	
6/06/2024	243	0	186		1,836		1,373		272	
7/06/2024	243	0	282		1,247		1,431		300	
8/06/2024	233	0	232		1,248		1,459		287	
9/06/2024	217	0	144		1,247		1,413		270	
10/06/2024	219	0	384		1,248		1,470		251	
11/06/2024	204	0	82		884		1,347		238	
12/06/2024	199	0	225		2,385		1,353		216	



Environmental Compliance Report

Sewage Treatment Plant Flow Summary
 Environment Protection Licence: 587, 579, 803 & 2564
 EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2			
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
13/06/2024	195	155	2		1,855		1,344		208	
14/06/2024	186	178	0		994		1,295		213	
15/06/2024	252	298	0		993		1,635		262	
16/06/2024	239	268	0		2,367		1,521		272	
17/06/2024	215	218	0		723		1,412		222	
18/06/2024	203	219	0		1,245		1,335		220	
19/06/2024	193	187	0		1,245		1,368		208	
20/06/2024	189	210	0		1,245		1,318		201	
21/06/2024	183	121	0		1,245		1,324		206	
22/06/2024	182	263	0		1,173		1,361		207	
23/06/2024	207	186	0		1,225		1,765		277	
24/06/2024	215	230	0		1,233		1,560		263	
25/06/2024	199	194	0		921		1,428		232	
26/06/2024	194	142	0		1,949		1,403		220	
27/06/2024	188	254	0		626		1,328		219	
28/06/2024	187	177	0		540		1,313		216	
29/06/2024	187	194	0		909		1,384		211	
30/06/2024	177	165	0		950		1,285		203	
1/07/2024	183	193	0		1,897		1,320		195	
2/07/2024	241	193	0		1,389		1,642		338	
3/07/2024	232	350	0		2,132		1,743		375	
4/07/2024	236	128	0		874		1,999		402	
5/07/2024	207	180	0		980		1,952		426	
6/07/2024	448	311	0		981		2,479		701	
7/07/2024	483	345	0		2,399		2,426		574	
8/07/2024	401	123	376		2,729		1,953		368	
9/07/2024	508	0	496		867		2,024		378	
10/07/2024	397	0	373		2,039		1,864		369	
11/07/2024	309	0	207		1,973		1,649		312	
12/07/2024	271	0	328		1,349		1,553		281	
13/07/2024	251	0	220		382		1,533		275	
14/07/2024	237	0	244		768		1,466		264	
15/07/2024	220	0	223		772		1,479		239	
16/07/2024	214	0	209		2,458		1,388		219	
17/07/2024	203	0	199		736		1,415		225	
18/07/2024	197	0	213		738		1,378		219	
19/07/2024	202	0	194		702		1,406		210	
20/07/2024	195	0	189	Internet down. Manual correction to Inflow & River discharge	518		1,397		218	



Environmental Compliance Report

Sewage Treatment Plant Flow Summary
 Environment Protection Licence: 587, 579, 803 & 2564
 EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2			
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
				Internet down. Manual correction to Inflow & River discharge						
21/07/2024	195	0	189		1,909		1,373		207	
22/07/2024	543	0	565		2,226		1,397		192	
23/07/2024	183	0	183		630		1,341		188	
24/07/2024	181	0	133		1,244		1,365		189	
25/07/2024	186	0	240		551		1,362		176	
26/07/2024	170	0	149		2,397		1,264		186	
27/07/2024	182	0	186		0		1,288		204	
28/07/2024	224	0	225		2,251		1,414		160	
29/07/2024	190	0	187		233		1,323		200	
30/07/2024	174	0	181		944		1,310		183	
31/07/2024	166	147	5		1,169		1,321		175	
1/08/2024	154	165	0		1,178		1,381		182	
2/08/2024	167	147	0		1,183		1,416		186	
3/08/2024	158	163	0		1,183		1,416		188	
4/08/2024	179	164	0		1,146		1,403		193	
5/08/2024	171	163	0		1,103		1,322		178	
6/08/2024	172	154	0		977		1,299		194	
7/08/2024	151	175	0		1,214		1,307		191	
8/08/2024	179	162	0		784		1,315		168	
9/08/2024	174	175	0		1,127		1,293		178	
10/08/2024	180	182	0		1,501		1,296		197	
11/08/2024	199	155	0		1,399		1,271		212	
12/08/2024	1,239	343	0		3,075		2,806		384	
13/08/2024	1,335	623	0		2,958		3,307		613	
14/08/2024	1,286	619	0		2,545		3,767		943	
15/08/2024	732	203	389		2,867		2,362		470	
16/08/2024	631	0	572		2,305		2,050		390	
17/08/2024	473	0	541		1,450		1,785		352	
18/08/2024	341	0	333		1,032		1,562		283	
19/08/2024	275	0	159		866		1,467		228	
20/08/2024	252	0	290		778		1,459		229	
21/08/2024	248	0	217		2,164		1,383		203	
22/08/2024	220	0	249		992		1,333		209	
23/08/2024	225	0	222		1,629		1,390		207	
24/08/2024	215	0	240		1,076		1,352		222	
25/08/2024	207	0	200		861		1,278		199	
26/08/2024	220	0	233		792		1,381		210	
27/08/2024	203	0	209		813		1,339		193	
28/08/2024	201	0	195		1,783		1,294		189	



Environmental Compliance Report

Sewage Treatment Plant Flow Summary

Environment Protection Licence: 587, 579, 803 & 2564

EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2			
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
29/08/2024	201	0	212		808		1,328		185	
30/08/2024	186	0	199		0		1,322		192	
31/08/2024	181	0	179		1,629		1,227		203	
1/09/2024	180	0	180		2,243		1,279		188	
2/09/2024	190	0	191		534		1,289		184	
3/09/2024	189	0	188		559		1,256		178	
4/09/2024	177	0	171		1,041		1,295		176	
5/09/2024	175	0	177		692		1,274		173	
6/09/2024	180	0	188		616		1,354		177	
7/09/2024	178	0	169		2,219		1,330		194	
8/09/2024	186	0	183		1,101		1,311		188	
9/09/2024	174	0	177		925		1,245		168	
10/09/2024	179	168	4		878		1,299		173	
11/09/2024	171	179	0		889		1,248		177	
12/09/2024	338	290	0		1,045		1,375		217	
13/09/2024	276	377	0		1,182		1,612		277	
14/09/2024	224	166	0		1,185		1,353		213	
15/09/2024	212	191	0		1,164		1,389		209	
16/09/2024	205	217	0		1,163		1,333		188	
17/09/2024	188	160	0		906		1,317		188	
18/09/2024	179	180	0		1,256		1,243		189	
19/09/2024	175	189	0		933		1,302		182	
20/09/2024	173	175	0		1,058		1,337		195	
21/09/2024	171	182	0		902		1,356		204	
22/09/2024	176	162	0		682		1,337		214	
23/09/2024	168	130	0		1,338		1,340		200	
24/09/2024	159	199	0		1,205		1,298		193	
25/09/2024	159	151	0		1,050		1,276		183	
26/09/2024	179	176	0		839		1,254		192	
27/09/2024	924	458	0		2,553		6,288		972	
28/09/2024	1,250	553	0		2,381		8,048		1,423	
29/09/2024	1,473	593	0		4,827		4,379		799	
30/09/2024	777	789	0		5,242		3,141		598	
1/10/2024	489	499	0		976		2,340		439	
2/10/2024	323	288	0		2,039		1,912		350	
3/10/2024	269	242	0		1,624		1,753		309	
4/10/2024	247	247	0		1,006		1,747		309	
5/10/2024	219	225	0		1,633		1,697		293	
6/10/2024	198	213	0		1,176		1,633		283	
7/10/2024	202	189	0		1,378		1,611		282	
8/10/2024	215	201	0		893		1,750		295	



Environmental Compliance Report

Sewage Treatment Plant Flow Summary

Environment Protection Licence: 587, 579, 803 & 2564

EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2			
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
9/10/2024	1,130	591	0		2,596		6,487		1,616	
10/10/2024	922	589	0		1,127		4,266		679	
11/10/2024	432	376	0		995		2,353		406	
12/10/2024	311	291	0		1,030		1,838		337	
13/10/2024	271	216	0		2,816		1,707		295	
14/10/2024	336	284	0		1,249		1,651		263	
15/10/2024	348	333	0		1,138		1,606		261	
16/10/2024	331	291	0		1,883		1,674		253	
17/10/2024	345	398	0		1,581		1,609		283	
18/10/2024	273	240	0		1,119		1,617		257	
19/10/2024	354	337	0		1,122		1,731		360	
20/10/2024	268	281	0		1,376		1,569		268	
21/10/2024	238	244	0		1,367		1,528		229	
22/10/2024	221	212	0		1,370		1,449		218	
23/10/2024	221	170	0		1,265		1,480		209	
24/10/2024	232	255	0		1,026		1,660		204	
25/10/2024	258	265	0		991		1,636		239	
26/10/2024	204	194	0		990		1,455		228	
27/10/2024	201	198	0		996		1,405		210	
28/10/2024	219	211	0		1,322		1,464		204	
29/10/2024	194	208	0		1,240		1,343		182	
30/10/2024	202	171	0		1,352		1,448		194	
31/10/2024	188	216	0		1,407		1,401		188	
1/11/2024	174	179	0		1,472		1,345		187	
2/11/2024	179	181	0		874		1,376		199	
3/11/2024	197	196	0		855		1,440		199	
4/11/2024	235	193	0		1,405		1,464		183	
5/11/2024	212	257	0		777		1,389		202	
6/11/2024	198	179	0		806		1,367		193	
7/11/2024	195	198	0		986		1,668		188	
8/11/2024	195	204	0		1,373		1,526		182	
9/11/2024	189	211	0		1,373		1,423		198	
10/11/2024	199	166	0		1,135		1,423		193	
11/11/2024	280	189	0		911		1,861		212	
12/11/2024	547	530	0		1,700		2,750		314	
13/11/2024	354	185	0		2,723		1,751		261	
14/11/2024	390	323	0		2,096		1,864		259	
15/11/2024	251	304	0		916		1,448		452	
16/11/2024	230	263	0		807		1,500		451	
17/11/2024	230	186	0		1,727		1,410		289	
18/11/2024	203	234	0		1,197		1,387		243	



Environmental Compliance Report

Sewage Treatment Plant Flow Summary

Environment Protection Licence: 587, 579, 803 & 2564

EPA Monitoring Point: 2, 3 & 4

01 Jan 2024 - 30 Nov 2024

Report Generated: Thursday, 05 December 2024

	Bowraville Sewage Treatment Plant				Macksville Sewage Treatment Plant		Nambucca Sewage Treatment Plant		Scotts Head Sewage Treatment Plant	
	Total Daily Inflow	Discharge to Reuse Dam Flow	Discharge to River Flow	Comments	Total Daily Discharge	Comments	Total Daily Inflow	Comments	Total Daily Inflow	Comments
	EPA Point 2	EPA Point 4	EPA Point 1		EPA Point 2		EPA Point 2		EPA Point 2	
Limit	1,500	-	-		9,500		12,600		2,500	
Units	kilolitres per day	kilolitres per day	kilolitres per day		kilolitres per day		kilolitres per day		kilolitres per day	
Minimum	0	0	0		0		0		0	
Minimum > 0	151	10	2		151		1,062		160	
Average	337	188	76		1,372		1,724		287	
Average > 0	342	260	270		1,410		1,750		292	
Maximum	2,953	789	746		8,379		9,286		1,802	
Exceedances	4	-	-		0		0		0	
Total	114,462	63,822	25,966		466,645		586,114		97,675	
No of Measurements	340	340	340		340		340		340	
No of Measurements > 0	335	245	96		331		335		335	